

# Wyoming Wind Collector System and Integration Study

Presented to

**Wyoming Infrastructure Authority  
Board of Directors**

Study Conducted for

*Wyoming State Energy Office and WIA*

*Jackson, WY*

February 1, 2011



# Outline

- Phase 1 Purpose
- Phase 1 Background
- Phase 1 Results
- Phase 2 Objectives
- Phase 2 Task 1 Results
- Phase 2 Task 2 Results
- Phase 2 Task 3 Results
- Possible Next Steps

# Phase 1 Purpose

- Determine whether a reliable collector system could be designed.
  
- Given:
  - Need to collect up to 12 gigawatts of wind generation
  - Need to connect 6 extra-high voltage transmission lines
  
- Without:
  - Picking winners and losers (i.e., where will wind be developed)
  - On the ground analysis

# Phase 1 Background

Proposed Transmission Line	Capacity (Megawatts)
Gateway South (PacifiCorp)	1,500
Gateway West (PacifiCorp)	1,500
Overland Intertie (LS Power)	2,000
Wyoming-Colorado Intertie (LS Power)	900
TransWest Express (Anschutz Corporation)	3,000
Zephyr (TransCanada)	3,000
<b>TOTAL</b>	<b>11,900</b>

# Phase 1 Results

- A reliable collector system can be designed
  - Collect up to 12 gigawatts of wind
  - Connect to 6 extra-high voltage transmission lines
  - Rough costs: \$2.5 to \$4.0 billion (\$210 to \$330 per kW)
    - May vary widely depending on design and where/how wind is developed

*Subsequent events, including a third drawing of the Wyoming Sage Grouse Core Area Map; continued development of transmission projects in the State; and the recent contracting of transmission capacity via the open season process indicate that a more compact, and less expensive, collector system may be adequate.*

*Lloyd Drain, Wyoming Infrastructure Authority*

# Phase 2 Objectives

- Location
  - Develop energy corridor constraints/opportunities criteria (Task 1)
  
- Financing
  - Assess financing options for Wyoming wind collector system (Task 2)
  
- Backup
  - Analyze backup scenarios for wind firming (Task 3)

# Task 1 – Energy Corridor Constraints and Opportunities

- Analyzed geospatial data for 8 counties in southeast Wyoming
- Created protocol for prepare a constraint/opportunity map
- Under separate contract ICF created map



## Task 2 – Financing Options for Wyoming Wind Collector System


- Evaluated 3 general types of financing options
  - Privately financed
  - Publically financed
  - Public-private partnerships
- Large Wyoming collector system will likely need public support
- Best financing alternative is likely a public-private partnership

## Task 3 – Wind Firming Scenarios

- Focused on evaluating capital costs associated with wind firming options, including:
  - Determining the amount of backup capacity required
  - Preparing capital cost estimates for physical assets
  - Developing scenarios to assess the capital cost of backup options

# Definition of “Firming Generation” and Backup Capacity Requirements

- If actual wind generation falls below the forecast, backup capacity is needed to make up the difference – this is “firming” generation.



# Results of Backup Analysis

- Historic differences between forecast and actual wind generation show a backup capacity equal to 25.8% of wind nameplate capacity.
  - 25.8% of 12,000 MW = 3,096 MW
  
- Backup capacity is a relatively small portion of total project costs.

# Options for Wind Backup Capacity

1. Gas-fired combustion turbines (Gas CTs)
2. Electricity storage technologies
  - New Gas CTs may require new natural gas pipeline and storage capacity.
  - Backup capacity and supporting infrastructure may be in Wyoming or California.



# Developing the Scenarios for Wind Firming

<i>Type of Backup Capacity</i>	<i>Location of Backup Capacity</i>	<i>New or Existing Infrastructure</i>	<i>Location of Gas Infrastructure</i>
<b>Gas CT</b>	Wyoming	Gas CT	Wyoming
	California	Gas Pipeline	California
		Gas Storage	
<b>Electric Storage</b>	Wyoming	New, Low Cost Electric Storage	
	California	New, High Cost Electric Storage	

# Matrix of Scenario Options

			Scenario Number									
			1	2	3 A	3 B	3 C	3 D	4 A	4 B	5 A	5 B
<b>Type of Backup</b>	Natural Gas		X	X	X	X	X	X				
	Electric Storage								X	X	X	X
<b>Combustion Turbine</b>	WY	New	X	X								
		Existing										
	CA	New					X	X				
		Existing			X	X						
<b>Gas Storage</b>	WY	New	X									
		Existing										
	CA	New		X	X	X	X	X				
		Existing										
<b>Gas Transmission</b>	WY	New	X	X		X		X				
		Existing			X		X					
	CA	New		X		X		X				
		Existing			X		X					
<b>Electric Storage</b>	WY	New						X	X			
		Existing										
	CA	New									X	X
		Existing										

# Capital Costs for Backup Capacity


<b>Cost Element</b>	<b>Wyoming New Build</b>	<b>California New Build</b>
Gas CT (\$/kW)	\$766 / kW	\$845 / kW
Gas Pipeline (\$/inch-mile)	\$48,960 / inch-mile	\$88,740 / inch-mile
Gas Storage (million\$/Bcf)	\$7 million / Bcf	\$10 million / Bcf
Electric Storage Low-cost Mix (\$/kW)	\$1,566 / kW	\$1,733 / kW
Electric Storage High-cost Mix (\$/kW)	\$3,135 / kW	\$3,465 / kW

# Breakdown of System Capital Costs

Scenario Number	Capital Costs (2009\$/kW)					Total Cost for 12 GW of Wind (Billion 2009\$)
	Wind Farms	Collector & Interconnection	Electric Transmission	Wind Energy Backup	Total (2009\$/kW)	
1	2,395 (same for all scenarios)	243 (same for all scenarios)	1,260 (same for all scenarios)	402	4,300	51.6
2				418	4,316	51.8
3 A				207	4,105	49.3
3 B				337	4,235	50.8
3 C				452	4,350	52.2
3 D				582	4,480	53.8
4 A				430	4,328	51.9
4 B				835	4,733	56.8
5 A				473	4,371	52.4
5 B				920	4,818	57.8


# Summary of Wind Backup Capital Costs

- Wind backup capital costs: \$207/kW to \$920/kW.
- Scenario 3a is lowest cost.
- Scenario 5B is highest cost.
- Scenario 1 is lower-to-middle end of costs.




# Summary of Capital Costs


**Lowest Cost (#3A)**  
*Use Existing CTs in CA*  
**\$4,105/kW**



**Low-to-Mid-Range Cost (#1)**  
*Build New Gas Backup in WY*  
**\$4,300/kW**



**Highest Cost (#5B)**  
*Build New Electricity Storage in CA*  
**\$4,818/kW**



## Summary of Conclusions from Phase 2

- Total capital costs: \$49 billion - \$58 billion (\$4,100 - \$4,800 per kW).
  - Backup capacity is relatively small percentage of total capital costs.
- Natural gas CTs are currently the most cost-effective means of providing backup capacity.
  - The lowest capital cost option is to rely on existing CTs and pipeline capacity to provide backup (if available).
- If new infrastructure is required, it would be less costly to build in Wyoming than in California.
  - Wyoming's abundance of natural gas may also give the state an advantage as a wind energy exporter.

## Possible Next Steps

- Foster public-private financing relationships
- Conduct more detailed cost analysis for firming assets
- Track federal policies and inform policy makers
- Examine cost recovery for wind firming options

# Thank You

**Phase 2 Report Available at: [www.icfi.com/collector](http://www.icfi.com/collector)**

## **Robert Henke**

Senior Vice President  
Denver, CO  
(303) 792-7810  
[rhenke@icfi.com](mailto:rhenke@icfi.com)

## **Frank Brock**

Senior Energy Market Specialist  
(703) 218-2741  
[fbrock@icfi.com](mailto:fbrock@icfi.com)